(A Government of Rajasthan Enterprise)

SBU & PC ROCK PHOSPHATE, Jhamarkotra Mines Dist. Udaipur - 313 015

Via. & Dist. Udaipur (Rajasthan) Phone: 2342441-43 Telefax: (0294) 2342444

E-mail: purchase.jkt@rsmm.com, satishk@rsmm.com Website: www.rsmm.com

ADDENDUM to NIT 38/14-15 dated 07/08/2014 for Replacement of Existing PLC with latest Technology PLC/PAC System

- A. The Sr. No. 1 & 2 of Notes mentioned in Annexure -C are replaced as under:-
 - 1. No. of channels in Digital Input & Output modules shall be 8 channels per module or more & shall be suitable for SIL-3 application.
 - 2. No. of channels in Analog Input modules shall be 4 channels per module or more & shall be with minimum resolution of 12 bit. No. of channels in Analog Output modules shall be 2 channels per module or more & shall be with minimum resolution of 12 bit.
- B. Following point may be added to Annexure- D of SCADA System Specifications:-
 - Two numbers of Licenses of SCADA software shall be provided. One WORKS edition required for SCADA development and one RUNTIME (Viewer) edition.

The tenderers are requested to please submit their offers taking into consideration the above addendum.

DY. GENERAL MANAGER (MM)