



RAJASTHAN STATE MINES & MINERALS LIMITED

(A Govt. of Rajasthan Enterprise)

Registered Office
C89-90, Lal Kothi Scheme, Janpath
Jaipur (Rajasthan) India
Ph.: +91-1410-2743734. 2743934
Fax: +91-141-2743735

CIN No.: U14109RJ1949SGC00050

PAN No : AAACR7857H

GSTIN No. 08AAACR7857 H120

Corporate Office

4, Meera Marg,

Udaipur – 313 001

Ph.: +91-294-2428768, 2428763-67

Fax: +91-294-24287, 2428739

e-mail naveengupta.rsmml@rajasthan.gov.in

website: www.rsmm.com

TENDER DOCUMENT

TO

e_TENDER NO. RSMM_CO_MM_NIT_13_2024-25

Dated 08.01.2025

Site study, design, manufacture, supply, installation, testing and commissioning of 12 nos 3 pole, 11KV, 50HZ VCB panels indoor type including voltage transformers, current transformers, metering instruments, indications, protection relays etc as per the technical specifications after dismantling the old HT panel from 33KV Sub-station as per terms and conditions of tender at Jhamarkotra mines located about 25 kms from Udaipur.

s.n.	Description	Date	Time
1	Bid Submission Start Date	16.01.2025	10.00 a.m.
2	Bid Submission Closing Date	29.01.2025	6.00 p.m.
3	Techno-Commercial Bid Opening Date	30.01.2025	3.00 p.m.
4	Submission Demand Draft / Bankers cheque/ Bank Pay Orders / RTGS/NEFT of Tender Document Fee, Processing Fees and Bid Security as per terms of tender	29.01.2025	Up to 6.00 p.m.
5	Price Bid Opening Date	Will be intimated later on to the techno-commercially qualified bidders	
6	Websites for downloading tender documents/ corrigendum etc.	www.rsmm.com , http://eproc.rajasthan.gov.in http://sppp.rajasthan.gov.in/	
7	Website for submission of tender/bid (only online)	http://eproc.rajasthan.gov.in	
9	Tender Document Fees	Rs. 1180/- (Inclusive of GST-18%) in favor of “Rajasthan State Mines & Minerals Limited” payable at Udaipur	
10	RISL Processing Fees	Rs. 1500/- in favor of “MD RISL” payable at Jaipur	
11	Bid Security	Rs. 165200/- in favour of “Rajasthan State Mines & Minerals Limited” payable at Udaipur as per tender terms.	



RAJASTHAN STATE MINES & MINERALS LIMITED

(A Govt. of Rajasthan Enterprise)

Registered Office
C89-90, Lal Kothi Scheme, Janpath
Jaipur (Rajasthan) India
Ph.: +91-1410-2743734. 2743934
Fax: +91-141-2743735

CIN No.: U14109RJ1949SGC000505

PAN No : AAACR7857H

GSTIN No. 08AAACR7857 H1Z0

Corporate Office
4, Meera Marg,
Udaipur – 313 001
Ph.: +91-294-2428768, 2428763-67
Fax: +91-294-24287, 2428739
e-mail naveengupta.rsmml@rajasthan.gov.in
website: www.rsmm.com

e_TENDER NO. RSMM_CO_MM_NIT_13_2024-25

Dated 08.01.2025

NOTICE INVITING e-TENDER

e- Tenders in Two parts (Techno Commercial Part & Price Part) are invited from VCB manufacturer or their authorized channel partner/dealer/distributor for following work-

Description	Qty.
Site study, design, manufacture, supply, installation, testing and commissioning of 12nos 3 pole, 11KV, 50HZ VCB panels indoor type including voltage transformers, current transformers, metering instruments, indications, protection relays etc as per the technical specifications after dismantling the old HT panel from 33KV Sub-station as per terms and conditions of tender at Jhamarkotra mines located about 25 kms from Udaipur.	12 Nos.
Required make of VCB: - ABB, Siemens, CGL, Schneider, L&T, Jyoti only Required make of Relay:- ABB, Siemens, CGL, C&S, Schneider, GE, L&T only	

For more details, visit us on web site www.rsmm.com, www.eproc.rajasthan.gov.in, www.sppp.rajasthan.gov.in or contact Dy. General Manager (MM) at the above address.

(L.S. Sardalia)
Group General Manager (MM)

e TENDER NO. RSMM CO MM NIT 13 2024-25

General	Instruction for preparation & submission of tender and General Conditions of e-Tender
Annexure- I	General profile of tenderer
Annexure- II	Undertaking towards acceptance of all terms & conditions of tender
Annexure- III	Undertaking towards non suspension/non banning and GST
Annexure- IV	Registration details as per Micro, Small & Medium Enterprises Development Act,2006.
Annexure- V	Details of taxes & duties offered in price bid
Annexure- VI, & VI, a	Check-list to technical specification and scope of work and other related details/drawings
Annexure-VII	Declaration by tenderer
Annexure- VIII	Details of Past Experience
Annexure- IX	B.G. format for Security Deposit.
Annexure- X	List of Public Sector Banks & Private Sector banks as per schedule II of the Reserve Bank of India Act, 1954.
Annexure- XI	Format of Undertaking for B. G.
Annexure- XII	Format of Bid security declaration.
Annexure- XIII	Format of Performance security declaration.
Annexure-A	Compliance with the Code of Integrity and No Conflict of Interest.
Annexure-B	Declaration by the Bidder regarding Qualifications.
Annexure-C	Grievance Redressal during Procurement Process and Form No. 1.
Annexure-D	Additional Conditions of Contract.
Form-A	Format of Application by MSME for Purchase Preference in Procurement of Goods
Form-B	Format of Affidavit

SECTION -1: Instructions for preparation & submission of e-Tender and Conditions of e-Tender:

Instructions for preparation & submission of tender:

- i) Tender shall be submitted online only through e-procurement portal of GoR i.e. www.eproc.rajasthan.gov.in.
- ii) No physical/offline Tender/bid shall be accepted.
- iii) The **Tender document fee** shall be in the form of Demand Draft/Bankers Cheque/Bank Pay Order/through RTGS/NEFT and **Bid Security** drawn **in favour of “Rajasthan State Mines & Minerals Limited” payable at Udaipur** shall be submitted to the office of the GGM(MM), 4-Meera Marg, Udaipur up to schedule date and time, as above.
- iv) The **Processing Fee** shall also be in the form of Demand Draft/Bankers Cheque/ Bank Pay Orders through RTGS/NEFT **drawn in favour of “MD RISL” payable at Jaipur** and shall also be submitted to the office of the GGM(MM), 4-Meera Marg, Udaipur up to schedule date and time, as above.
- v) Conditional tenders and casual letters sent by the bidders will not be accepted.
- vi) Bidders are requested to read the instruction in the Tender Document/Bid before submitting the Tender/BID online.
- vii) The Tender Document is not transferable.
- viii) Bidders who wish to participate in this tender will have to be registered on <http://eproc.rajasthan.gov.in>. To participate in online tenders, bidders will have to procure Digital Signature Certificate (type II or III) as per Information Technology Act-2000 using which they can sign their electronic bids. Bidders can procure the same from any CCA approved certifying agency or may contact Government of Rajasthan e-procurement Cell, Department of IT&C for further assistance. Bidders who already have a valid Digital Certificate need not to procure a new Digital Certificate.
- ix) Contact details of Government of Rajasthan e-procurement Cell, Department of IT&C are:
The 24 x 7 Help Desk Telephone No. 0120-4200462, 0120-4001002, 8826246593, (Local Help Desk No. 0141-4022688 available all working days between 9.30 AM to 6.00 PM), email: eproc@rajasthan.gov.in, support-eproc@nic.in. Address: e-procurement cell, RISL. Yojana Bhawan, Tilak Marg, C-Scheme, Jaipur.
- x) Training for the bidders on the usage of e-Tendering system is also being arranged by RISL on regular basis. Interested bidders may contact e-Procurement Cell, RISL.
- xi) Bidder shall submit their offer on-line in electronic formats both for techno-commercial and financial bid, however Demand Draft/Bankers Cheque/Bank Pay Orders /RTGS/NEFT for Bid Security, Tender Fees & Processing Fees should be submitted offline (manually/post/courier) to the office of GGM (MM) before scheduled date & time as mentioned in tender document. Scanned copies of Demand Daft/Bankers Cheque/Bank Pay Orders/RTGS/NEFT should also be uploaded along with the online Bid.
- xii) Before electronically submitting the tenders, it should be ensured that all the tender papers including conditions of contract are digitally signed by the tenderer.

- xiii) Bidders are also advised to refer “Bidders manual” available under “Download” section for further details about the e-tendering process.
- xiv) All bidders are advised not to wait for last date and submit their tender/bid at earliest. The Company shall not be responsible for any interruption/technical snag in website and No extension in deposition of Tender/bid shall be allowed.
- xv) Bidders shall have to furnish the legible/readable bid documents in the “covers” as prescribed in the document in PDF/jpg format. **All the documents should be sealed & signed by the tenderer.**
- xvi) Provisions of Rajasthan Transparency in Public Procurement Act,2012 and Rajasthan Transparency in Public Procurement Rule,2013 & subsequent amendments time to time, will also be applicable.
- xvii) In compliance to the Rajasthan Transparency in Public Procurement Act,2012 and Rajasthan Transparency in Public Procurement Rule, 2013, following annexures are enclosed:
 - i) Annexure-A- Compliance with the Code of Integrity and No Conflict of Interest.
 - ii) Annexure-B- Declaration by the Bidder regarding Qualifications.
 - iii) Annexure-C- Grievance Redressal during Procurement Process and Form No. 1.
 - iv) Annexure-D- Additional Conditions of Contract
 - v) Form-A, format of application by MSNE for purchase preference in procurement of goods.
 - vi) Form -B, format of affidavit.

COVER-A

- i) Scanned Copies of Demand Draft/Bankers Cheque/Bank Pay Orders /NEFT/RTGS details towards Tender document Fees, Processing fees and Bid Security.
- ii) Authorization in favor of a person signing tender document.
- iii) General profile of tenderer as per annexure-I, undertaking towards acceptance of all terms & conditions of tender as per annexure-II and Undertaking towards non suspension/non banning /GST as per annexure-III.
- iv) Registration details as per MSMED Act, 2006 as per annexure-IV.
- v) Details of taxes & duties offered in price bid as per annexure-V.
- vi) Details of the offices from where after sales services will be provided by the manufacturer at site. In case the tenderer proposes to develop any additional sales service center at Udaipur those also be detailed.

COVER-B

- vii) Check-list to technical specifications as per annexure VI & VI.a.
- viii) Declaration as per annexure-VII along with documents. In case of authorized dealers/channel partner, submit the authorization certificate from the respective VCB manufacturer.
- ix) Details as per annexure-VIII along with copies of PO and installation/commissioning certificates in support of PQC as per clause no. 8.0.
- x) Detailed specifications and illustrated catalogue and specific technical information, if any.

- xi)** List of standard tools & accessories to be supplied on free of cost basis.
- xii)** Undertaking in support of PQC as per clause no. 8.0 (b) of tender.
- xiii)** Type test reports of VCB panels i.e. Temp rise, short circuit impulse, IP 4X and internal arc test 26.3KA for 1sec.
- xiv)** Sealed and Signed copies of Annexure-A, Annexure-C, Annexure-D and Duly Filled, Sealed and Signed Annexure-B.
- xv)** Form A and B.

COVER-C

- **Price Bid in Excel format.**

2.0 SUBMISSION & OPENING OF TENDERS:

The online submission of bids on the e-procurement portal i.e. <http://eproc.rajasthan.gov.in> within the specified date and time will be the sole responsibility of the Tenderers. In case the date of opening of bids happens to be a holiday, then the bids shall be opened on the next working day.

Tenderers are requested to ensure submitting their tender online on e-procurement portal only and furnishing Demand Draft/Bankers Cheque/Bank Pay Orders towards Tender Document Fee, Processing Fee and Bid Security offline to the office of GGM (MM) within the specified time & date of submission. Tenders in physical form (offline) will not be acceptable in any case.

Tenderers may note that they will not be able to submit their tenders online after the specified/scheduled date & time of submission of bid document. Tenderers should also ensure furnishing Demand Draft/Bankers Cheque/Bank Pay Orders towards tender document fee/Bid Security /Processing Fees to the office of GGM (MM) within the specified time & date of submission, failing which, their online bids will not be opened.

3.0 VALIDITY:

The tenderer shall keep the offer open for acceptance by RSMML for a minimum period of 4 months from the date of opening of tender (Part-I), within which period the tenderer shall have no right to withdraw, cancel, amend or modify his offer. In case of withdrawal/cancellation/ amendment/ modification in the offered tender, the Bid Security deposited by the tenderer shall stand forfeited. The validity period may be extended further, if required, by mutual consent from time to time.

In case, tenderer, after issuance of communication of acceptance of offer (LOA/PO) by RSMML, fails to execute the contract as per the conditions therein, such an event will be considered as the tenderer's calculated willful breach of the contract. The cost & consequence in such cases shall be on the sole account of the tenderer. Moreover, RSMML have full right to claim damages thereof in addition to the forfeiture of Bid Security.

4.0 BID SECURITY, TENDER DOCUMENT FEES & PROCESSING FEES:

- a) Bid Security of Rs. **1,65,200/-**, will be furnished by the bidder in favour of RSMML by RTGS/Demand Draft/Bankers Cheque/ Bank Pay Orders /RTGS/NEFT only to the office of GGM(MM) within the specified date & time. Offers not accompanied with the requisite Bid Security will not be considered.
- b) Tenderers shall deposit a sum Rs. **1,180/-** towards tender document fees and Rs. **1500/-** towards processing fees by RTGS/Demand Draft/Bankers Cheque/ Bank Pay Orders / RTGS/NEFT only to the office of GGM(MM) within the specified date &

time. The details of furnishing such financial instruments are elaborated in clause no.1.0. Payments through Cash, Cheque or Bank Guarantee will not be accepted.

Demand Draft/Bankers Cheque/Bank Pay Orders/RTGS/NEFT for Tender Fees, Processing Fees should be submitted offline (personally/post/courier) to the office of GGM(MM) before scheduled date & time as mentioned in tender document. Scanned copies of Demand Draft/Bankers Cheque/ Bank Pay Orders/ RTGS/NEFT should also be uploaded along with the online Bid. The tender document fees & processing fees are non-refundable.

Bid Security, Tender Document Fees & Processing Fees may also be furnished by the way of RTGS/NEFT in the account of RSMML in addition to other modes already prescribed in the relevant clauses of the tender document.

Our Bank Details are as under:

IDBI Bank,
Account No.:050102000002202
IFSC Code: IBKL0000050
Saheli Marg, Udaipur (Raj.) India

Note: Tenderes are requested to forward the UTR no. & other relevant details through email immediately after deposition of Tender Document fees & Processing Fees through RTGS/NEFT for verification at our end.

5.0 SECURITY DEPOSIT CUM PERFORMANCE GUARANTEE:

- i) As security for the due, proper and faithful fulfillment of the obligations under the contract, the tenderer will furnish to RSMML Security Deposit cum Performance Guarantee equal to 5 % of total value of contract in the form of Demand Draft /RTGS/NEFT or in the form of Bank Guarantee in RSMML Performa by public Sector Banks & Private Sector banks as per schedule II of the Reserve Bank of India Act, 1954 as per list enclosed at annexure-X having its Branch at Udaipur, within 21 days from the date of LOA/PO on the stamp paper of appropriate value. An undertaking as per annexure-XI will also be submitted along with the B.G. The Bank Guarantee should be valid for a period of 6 months in excess of warranty period + delivery period.

Security Deposit Cum Performance Guarantee” may also be furnished by the way of FDR in addition to existing methods mentioned in tender. FDR should be furnished as per provisions of RTPP Rule 75(3)(e), as below-

"Fixed Deposit Receipt (FDR) of a scheduled bank. It shall be in the name of procuring entity on account of bidder and discharged by the bidder in advance. The procuring entity shall ensure before accepting the Fixed Deposit Receipt that the bidder furnishes an undertaking from the bank to make payment/premature payment of the Fixed Deposit Receipt on demand to the procuring entity without requirement of consent of the bidder concerned. In the event of forfeiture of the performance security, the Fixed Deposit shall be forfeited along with interest earned on such Fixed Deposit".

- ii) The BG shall liable to be invoked/ amount of SD is liable to be forfeited wholly or partly at the sole discretion of the Company, should the supplier either fails to execute the work within the stipulated period or fails to fulfill the agreed obligations or fails to settle in full it's dues to the Company.

- iii) The Company is empowered to recover from the S.D. any sum due and /or any other sum that may be fixed by the Company as being the amount or loss or losses or damages suffered by it due to un-satisfactory performance or non fulfillment of any of the conditions of the tender/ contract.
- iv) The Bank Guarantee/S.D. shall remain in force and binding, notwithstanding, if any variation, alternation, modifications are made to the contract or any extension of the contract period is granted by RSMML.
- v) RSMML shall not pay any interest on the Security Deposit. The security Deposit shall be released on application by the Supplier after the expiry of guarantees and after discharge of all the supplier's obligations under the contract.
- vi) The said Security shall not in any way be construed as a limitation of the supplier's responsibility or liability pertaining to its obligations and guarantees under the contract and shall be without prejudice to any other remedies available to RSMML in terms of the contract and/ or as per the laws of the land.
- vii) Incase SD is being furnished in the form of Bank Guarantee, the BG should be furnished on the non-judicial stamp paper of the value equal to 0.25% (Zero Point Twenty Five Percent) of total Security Deposit amount subject to the maximum of Rs. 25000/- or as applicable at the time of submission of B.G.
- viii) S.D. should be sent to the office of GGM (MM), CO, Udaipur.

6.0 RELAXATION IN TENDER DOCUMENT FEES, BID SECURITY & SECURITY DEPOSIT CUM PERFORMANCE GUARANTEE TO MSME, GOR:

- (A) Tenderers offering in capacity of micro, small and medium enterprises of the State Rajasthan, having acknowledgement of Entrepreneurs Memorandum-II/Udyog Aadhaar Memorandum as mentioned in Micro, Small and Medium Enterprises Development Act, 2006, issued by the competent authority facilitated, on furnishing of a self-attested copy of acknowledgement of Entrepreneurs Memorandum-II/Udyog Aadhaar Memorandum, following relaxations will be provided, if sought by the bidder-
 - i) Tender document fees will be taken @50% of the prescribed total value of Tender document fees.
 - ii) Bid Security will be taken @25% of the total value of Bid Security. In case of offering the quantity lesser than the tendered quantity, then they can submit proportionate amount of bid security in proportion to the quantity being offered with respect to the bid security amount for tender quantity.
 - iii) Security Deposit will be taken @ 0.5% of the total value of order.
- (B) In case of participation by Undertakings, Corporations, Autonomous Bodies which are controlled and managed by Govt., Govt. Undertakings and Companies of Union Govt. & Govt. of Rajasthan, they are exempted from deposition of Bid Security & Security Deposit, however, they will have to furnish declaration as per annexure-XII & XIII.

Except above, no exemption in respect of Tender Document Fee, Bid Security & Security Deposit (Performance Security) will be given to any party on any grounds (except considered by management on the merit of the case) and their offer will be liable for rejection.

7.0 SCOPE OF WORK & SPECIFICATIONS:

Site study, design, manufacture, supply, installation, testing and commissioning of 12nos 3 pole, 11KV, 50HZ VCB panels indoor type including voltage transformers, current transformers, metering instruments, indications, protection relays etc as per the technical specifications after dismantling the old HT panel from 33KV Sub-station as per terms and conditions of tender at Jhamarkotra mines located about 25 kms from Udaipur.

Required make of VCB: - ABB, Siemens, CGL, Schneider, L&T, Jyoti only

Required make of Relay:- ABB, Siemens, CGL, C&S, Schneider, GE, L&T only

Details of work is given as per Annexure-VI & VI, a. Tenderer is requested to give details of their offered item/acceptance therein against each specification details.

Note- Tenderers are requested to visit the site to understand the scope of work under the tender. No claim on this account will be entertained by the company at any point of time. Jhamarkotra mines is situated about 25 Kms from Udaipur (Rajasthan).

8.0 PRE-QUALIFICATION CRITERIA:

1. (a) Only VCB manufacture or their authorized channel partner/dealer can quote for this VCB panel. In case of authorized dealers/channel partner, they will submit the authorization certificate from the respective VCB manufacture on behalf of whom they are quoting.

(b) Authorized channel partner/dealer should have their own inhouse manufacturing facility for these VCB panel and pre-dispatch inspection of these panels shall be carried out at same place. In case of non-manufacturing facility of these panel of bidder, they shall manufacture VCB panels at OEM works of VCB and site inspection shall also be carried out at OEM works. Bidder will provide undertaking for this aspect in their offer.
2. The bidder should submit the documentary evidence for Supply, installation, testing & commissioning of at least ten numbers of 11KV or higher ratings VCB panels during last five years i.e. 2019-20, 2020-21, 2021-22, 2022-23 & 2023-24.
3. For installation work, supplier shall have valid A-class Electrical Contractor License issued by the Electrical Inspector, Govt. of Rajasthan or work of installation & commissioning shall be arranged through the contractor having A-class Electrical Contractor License issued by the Electrical Inspector, Govt. of Rajasthan. Before installation, supplier shall submit A-class contractor License as above.

Note- The bidder should furnish copies of documents in support of above PQC.

The Techno-commercial suitability of the offers will be ascertained on the basis of pre-qualification criteria, documents submitted along with Part –I of the offer and/or the information gathered by the RSMML about the tenderer. The price offer of only techno-commercially qualified Tenderer(s) will be opened on a later date, which will be informed to qualified Tenderer(s) only . The decision of the Company shall be final and binding in this regard.

9.0 CONSIGNEE:

The Group General Manager, SBU&PC(RP)
or his authorized officer.
PO. Jhamar Kotra Mines-, Udaipur (Raj)

10.0 RSMML's RIGHT:

The Company reserves the following rights at its sole discretion without assigning any reason thereof:

- a) to reject any or all the tenders received.
- b) to accept or not to accept the offer of lowest tenderer.
- c) To accept/reject any tender on technical grounds based on RSMML requirement.
- d) to cancel the tender, postpone it for another date, change the venue of the receipt of the tender.
- e) to increase/decrease the quantity as per work requirement.

The decision of the Company in above regards shall be final and binding on the tenderer. As a result of such change the Company will not entertain any claim whatsoever.

11.0 RATES :

- i) The price should be quoted on-line in Indian Currency strictly in Price Bid (BOQ) Cover – C on f.o.r. destination basis.
- ii) **Tenderer (s) are requested to offer prices strictly in the BOQ uploaded on the site. They should first download the BOQ from the site on their system and after filling it, the same BOQ should be uploaded on the e-procurement portal. Further, tenderers are advised to recheck the filled prices of each item to its correctness before uploading the BoQ on portal. RSMML will not entertain any claim on this account at any point of time.**
- iii) The quoted price shall be on F.O.R. destination basis inclusive of basic price, Taxes, Duties, Levies, Packing, Forwarding, Transportation, Insurance, any other Delivery Charges etc. up to destination. The quoted price will remain firm and fixed till complete execution of the contract.
- iv) Timely deposition of GST and filing of requisite tax returns of relevant tax period would be the sole responsibility of the supplier. The supplier will also ensure that necessary credit on this account is available to RSMML in the next month. In case of any discrepancy, where credit is not available to RSMML, then company is free to deduct/recover/retain such amount from the bills of supplier or any other amount due to him/or from Security Deposit, as the case may be.
- v) In case of reversal of Input Tax Credit (ITC), imposition of penalty on account of payment of GST and default in filing of returns towards the payment for the work, supplier is liable to pay all such dues to the company, failing which RSMML is free to deduct/recover/ retain such amount from the bills of supplier or any other amount due to him/or from Security Deposit, as the case may be.
- vi) The bidder shall submit an undertaking with bills bearing GSTIN and HSN/SAC Code that " total GST has been deposited and returns have been filed for relevant tax period."

- vii)** In addition, a general undertaking shall also be furnished by the bidder at the time of submission of bid that "as on date, no default has been made by us towards payment of GST and all returns up to the last date of submission of bid have been filed by us."

12.0 PRICE VARIATION:

- i)** The agreed price shall remain firm and fixed till the complete execution of the contract. Only variation on account of withdrawal/imposition/changes in structure of Taxes & Duties by the Government will be considered on production of documentary proof.
- ii)** Save and except as aforesaid, the tenderer shall not be entitled to raise any claim and/or demand and/or any dispute on account of escalation or raise or increase in the prices of any other item or element.

13.0 GUARANTEE/ WARANTEE:

The supplier shall guarantee/warranty against any manufacturing defect/poor workmanship/inferior design/quality etc. for a period of minimum 12 months from the date of commissioning of store. In case of any defects is observed during the guarantee/warranty period, supplier will arrange to repair/replace the same free of cost or replace complete item/s, as required. In case, if supplier fails to replace/repair the defective material then the work shall be got done by the RSMML and recovery shall be made from supplier.

14.0 DETERMINATION OF LOWEST BIDDER FOR EVALUATION PURPOSE:

- a)** The lowest tenderer shall be determined on the basis of total landed price for complete scope of work as per tender at our Jhamarkotra mines including all prices, all taxes & duties, transportation, insurance and all other charges etc. up to destination (**EXCEPT GST**).
- b)** Online comparative chart may not necessarily be generated and if generated, it may not be treated as final because of method of determination of lowest tenderer as detailed above.

c) NEGOTIATIONS:-

- i)** Negotiations may be conducted with the lowest tenderer only. In case of non-satisfactory achievement of rates from lowest tenderer, RSMML may choose to make a written counter offer to the lowest tenderer and if this is not accepted, RSMML may decide to reject and re-invite fresh tenders or to make the same counter-offer first to the second lowest tenderer, then to the third lowest tenderer and so on in the order of initial bidding, and work order be awarded to the tenderer who accepts the counter offer.
- ii)** In the case, when the quotations given by the tenderer during negotiations is higher than the original quotation of the tenderer then the tenderer will be bound by the lower rate originally quoted by the tenderer.
- iii)** In case of negotiations, representative of the tenderer attending negotiations must possess written authority from the tenderer to the effect that he is competent to modify/amend the submitted tender deviations and rates offered by them.

- d) In the event the company does not find the lowest quoted rate, acceptable to it, then the tender will be scrapped and may be re-invited, or company may take any other suitable action as deemed fit looking to the exigency of the work.

15.0 WORK COMPLETION PERIOD:

The tenderer is to offer the minimum possible work completion period for total scope of work as per tender. The work completion period will be counted from the date of PO.

16.0 INSPECTION & TEST:

- i) RSMML shall have the right to inspect and/or to test the goods to confirm their conformity to the contract.
- ii) Supplier shall arrange for pre-dispatch inspection at manufacturer's works for RSMML Engineer. Supplier should demonstrate the specifications. Supplier has to ensure all the relevant test set up. Supplier shall provide all the test facilities at free of cost for carrying out the routine tests. The Circuit Breaker shall be tested for the routine tests as mentioned in the relevant latest Indian Standards, before dispatch in the presence of RSMML Engineer and test certificate shall be provided in triplicate.
- iii) However, the final inspection shall be carried out at consignee's end after receipt of the material at site which will be final and binding to both parties. All reasonable facilities and assistance including access to technical data, drawings etc. shall be furnished by the tenderer to the inspector at no charge.
- iv) In case of rejection of any item, the same would have to be replaced, to meet specification requirements, by the tenderer at their own risk & cost.
- v) RSMML's right to inspect, test and, where necessary, reject the items after the arrival at RSMML site shall in no way be limited or waived by reason of the items having previously been inspected, tested and passed by the RSMML or its representatives prior to the shipment of the goods.
- vi) The inspection/test reports shall in no way release the tenderer from any warranty or other obligations under this contract.

17.0 TERMS OF PAYMENT & PAYING AUTHORITY:

- i) 90% payment within 30 days from the date of completion of complete work as per tender at site. Balance 10% payment thereafter within 15 days.
- ii) The bill in triplicate along with the supporting documents duly verified by the consignee will be submitted to The Office of GGM (MM), CO, 4 – Meera Marg, Udaipur for payment purpose. The payment disbursing authority is-

The Financial Advisor,
Rajasthan State Mines & Minerals Ltd.
4, Meera Marg, Udaipur-313001

- iii) Payment will be made through NEFT/RTGS.
- iv) Payment will be made after deducting statutory taxes wherever applicable.

18.0 COMPENSATION FOR DELAYED DELIVERY:

In the event of the tenderer fails complete the work as per scope of work of tender within the scheduled work completion period or the stores are rejected, the Company shall be entitled at its option either:

- a) to recover from the supplier as agreed pre determined compensation @ 1/2% (Half percent) per week of the total value of work for each week or part thereof for which completion has been delayed, subject to a maximum of 5% of the total value of work,

- b) either to purchase from elsewhere, without notice to the supplier at his risk and cost full or undelivered part, as the case may be

OR

- c) to cancel the contract.

In case of b & c above, the Company will be empowered to purchase stores which are readily available with alternative source to meet the requirement irrespective of the fact whether these are similar or not.

19.0 EXCEPTION & DEVIATION/ ACCEPTANCE OF ALL THE TERMS & CONDITION OF TENDER:

Tenderers are advised to submit their offer based on terms & conditions and specifications contained in the tender document and not to stipulate any deviations. Offer containing stipulations of deviations to the terms & conditions are liable to be ignored. However, in case it is absolutely unavoidable to deviate from tender conditions then the tenderers should mention the deviations at their risk of rejection only in Annexure- II. Deviations mentioned anywhere else in the offer shall be ignored without any consequences.

- i) Tenderer should mention the deviations, if any, at their own risk of rejection of their offer.
- ii) Deviations mentioned anywhere else in the offer shall be ignored without any consequences.
- iii) Tenders containing corrections and alterations are liable to be rejected unless all such corrections and alterations are legible, clear and signed by the tenderer. Tenders containing corrections and alterations are liable to be rejected unless all such corrections and alterations are signed by the tenderer.

20.0 NO COMPENSATION FOR ALTERATION OF DELIVERY SCHEDULE OR SUSPENSION OF SUPPLIES:

If at any time before commencement of the supply if the Company, for any reason, whatsoever do not require the whole supply or part thereof as specified in the PO, shall give notice in writing of the same to the supplier and the supplier shall not be entitled for any compensation and/or damage of any kind whatsoever on account for loss or profit etc. nor the supplier be entitled to any claim for compensation for re-scheduling of delivery period.

21.0 ASSIGNMENT:

The supplier shall not sublet, transfer or assign this contract or any part thereof (or any benefit or interest therein and there under) without written consent of the company. But such consent of the company, if given shall not relieve the supplier from any liability or obligation under this contract and the supplier shall be responsible for all acts, defaults and neglects of the sub-contractor, his agents and employees fully as if those are the Supplier 's own acts.

22.0 INDEMNIFICATION: Except were arising from the negligence of RSMML or RSMML's employees, the tenderer shall indemnify RSMML in respect of any costs or damages, whatsoever arising out of or related to breach of statutes, laws, acts, rules and regulations, damage, accident or loss etc. by the tenderer or tenderers personnel or by claims made against RSMML by third parties in respect thereof.

23.0 INDIAN / INTERNATIONAL STANDARD: The offered specification by the tenderer should be based upon Indian standards or equivalent and where no Indian standards exist the supplies should conform to international standards. All

electric installations, equipment shall have to conform to Indian Electricity Rules 1967 and as amended from time to time. The equipment covered by specification shall, unless otherwise specified be build to conform to the requirements of relevant standards issued by any of the following or any other standard as applicable and the tenderer should specifically mention in each case the applicability of the relevant latest standard.

1. Bureau of Indian Standard's Standard Codes and specifications wherever applicable. (ISI)
2. Indian Electricity Rule 1956, wherever applicable.
3. British Standard Specification, relevant Code and British Electrical Standard Association.
4. American Society of Mechanical Engineer's Power Test Codes.
5. American Society of Materials Testing Codes.
6. American Standards Association/ USA Standards Institute and Edison Electric Institute
7. Standard of Hydraulic Institute, USA
8. Heat Exchanger manufacturer's Association, Standards, USA
9. Bleeder Heater Manufacturer's Association, Standards, USA.
10. Appropriate national Standard Specification of the country of manufacture on approval by the purchaser.
11. Indian Boiler Regulation Act.
12. Indian Electricity Act. 1910.

24.0 PATENTS :

Tenders shall warrant that all equipment or material furnished hereunder are and shall be free and clear of infringement of patent and copy right or trade mark prevalent, if any country.

25.0 COMPLIANCE OF RULES/GUIDELINES OF MINISTRY OF ENVIRONMENT AND CLIMATE CHANGE (MOEFCC).

The supplier will ensure compliance of the rules/guidelines of Plastic Waste Management (Amendment) Rules, 2021 and its amendments from time to time as indicated in gazette notifications of the Ministry of Environment, Forest and Climate Change (MoEFCC), Government of India & Rajasthan State Pollution Control Board (RSPCB), wherever applicable.

26.0 TERMINATION:

- a) In case of failure to perform the job as required under this contract or observe breach of any of the terms and conditions by the tenderer, the company shall give a notice to rectify the default or breach within 10 days. Failure to rectify such default/ breach may result in termination of the contract and forfeiture of security deposit without any prejudice to the company's rights to claim damages/costs/loss etc caused by such default/breach. Such termination shall not absolve the tenderer of the liabilities accruing till the date of such termination.
- b) The contract may also be terminated in the event the tenderer is being adjudged insolvent or going into Liquidation or Winding up of their business, or making arrangement with their creditors.
- c) Notwithstanding anything contained herein above, the company in its absolute discretion may at any time terminate the order without assigning any reason thereof by giving Fifteen day's notice to the tenderer at their last notified address. In such an event the tenderer shall not be entitled to raise any claim or demand for compensation, loss of profit and/or damages and/or losses or costs by reason of such earlier termination on any ground whatsoever.

27.0 FORCE MAJEURE:

At any time, during the continuance of the contract, the performance in whole or in part by either party (sub-vendors excluded) and/or obligations under this contract shall be prevented or delayed by reason of any war, Hostility acts of public enemy, civil commotion, sabotage, fires, floods, explosion, epidemics, quarantine restrictions, non-performance due to Acts of God or Acts of Government /statutory bodies (herein after referred as "Event") then provided a notice of the happening of any such event is given within seven days from the date of occurrence thereof neither party shall by reason of such event be entitled to terminate this contract nor shall either party have any claim for damage against the other in respect of such non-performance or delay in performance and the deliveries and/or performance of the work under the contract shall be resumed as soon as practicable after such event has come to an end or ceased to exist and decision of Company as to whether the deliveries and/or performance of the work have been so resumed or not shall be final and conclusive. Provided further that if the performance in whole or in part is delayed by reasons of any such events for a period exceeding thirty days either party may at its option terminate the contract.

28.0 JURISDICTION:

The contract is subject to the jurisdiction of courts at Udaipur only in the state of Rajasthan.

For RAJASTHAN STATE MINES & MINERALS LIMITED,

(L.S. Sardalia)
Group General Manager (MM)

I/We have studied the above terms and conditions and having understood the same in true sense and spirit, I/We shall abide by and adhere to the above terms and conditions fully.

Signature of Tenderer with official stamps

Place & Date:

e_TENDER NO. RSMM_CO MM NIT_13_2024-25
GENERAL PROFILE OF TENDERER

1	Name & address of the tenderer with Telephone No., Mobile no. Fax No., e-mail address etc.			
2	Date of establishment.			
3	Whether Proprietor/Partnership/ Company			
4	Name of owner/partners Directors with full address.			
5	Annual turnovers in rupees for last three years.	2021-22	2022-23	2023-24
6	PAN No.			
7	GSTIN No.			
8	HSN Code of offered item			
9	Entrepreneurs Memorandum no. as per MSMED Act 2006 Nature of Activity (manufacturing/Service) Category of Enterprise: (Micro/ Small/ Medium)			
10	Banker details for payment purpose: i) Name ii) Branch No. iii) Address			
11	Bank Account No.			

12	Type of A/c : Saving / Current/CC/ any other	
13	IFSC code	
14	WORK COMPLETION PERIOD FOR COMPLETE SCOPE OF WORK FROM THE DATE OF ISSUE OF PURCHASE ORDER.	

Signature of tenderer with official stamp

Date & Place:

e_TENDER NO. RSMM_CO_MM_NIT_13_2024-25**UNDERTAKING TOWARDS ACCEPTANCE OF ALL TERMS & CONDITIONS OF TENDER**

Name of Tenderer_____

We confirm that all the terms & conditions of tender are acceptable to us except the following.

Tenderer may stipulate here exceptions and deviations to the tender conditions, if considered unavoidable. In case the tenderer does not mention any information to the deviations in the below format & furnish it blank then it will be presumed that the tenderer is not offering/ putting any deviations to the tender terms & condition. Tenderer should mention the deviations, if any, at their own risk of rejection of their offer.

S.No.	Tender Clause no.	Requirement as per tender clause	Offered condition/ Deviation

Company may accept or may not accept the deviations put by the tenderer at its sole discretions. No claim on this will be entertained.

Note: Deviation to the tender terms, if any, mentioned anywhere else (i.e. in any other document furnished in support of tender will not be considered & accepted. RSMML will not entertain any claim of the tenderer on offered deviations mentioned anywhere else.

Signature of tenderer with official stamp

Date:

Place:

e_TENDER NO. RSMM_CO_MM_NIT_13_2024-25

UNDERTAKING TOWARDS NON-SUSPENSION/NON-BANNING/GST

Name of the Tenderer: _____

- a) We hereby declare that we have not been banned/suspended or de-listed by RSMML or any other procuring entity in past as per points of annexure-A.
- b) We undertake that "as on date, no default has been made by us towards payment of GST and all returns up to the last date of submission of bid have been filed by us."

Signature of Tenderer with official stamp

Place:
Date:

e_TENDER NO. RSMM_CO_MM_NIT_13_2024-25

**Declaration for Registration under Micro, Small & Medium Enterprises
Development Act, 2006.**

1. Whether the tenderer is registered under Micro, Small & Medium Enterprises Development Act, 2006. _____(Yes/NO).
2. If yes, please furnish the declaration given below.
3. We (Name of Tenderer_____), hereby declare that, our organization is registered under Micro, Small & Medium Enterprises Development Act, 2006 as _____ (Micro, Small & Medium) Enterprises having entrepreneurs Memorandum no. and under category of(Manufacturer/Service).
4. **Enclose attested copy of registration certificate under MSME having entrepreneurship no.....**

Signature of tenderer with official stamp

Date:

Place:

e_TENDER NO. RSMM_CO_MM_NIT_13_2024-25**DETAILS OF TAXES & DUTIES OFFERED IN PRICE BID**

Name of Tenderer_____

Particulars	% Rate considered in price bid
CGST	@.....%
SGST	@.....%
IGST	@.....%

Signature of tenderer with official stamp

Date:

Place:

e_TENDER NO. RSMM_CO_MM_NIT_13_2024-25

Required make of VCB: - ABB, Siemens, CGL, Schneider, L&T, Jyoti only**Mention Offered make & Model of VCBs out of above makes:****Required make of Relay:-** ABB, Siemens, CGL, C&S, Schneider, GE, L&T only**Mention Offered make & Model of Relay out of above makes:****Quantity-** 12 Nos.

Sl. No.	Description	Agreed/Deviation, if any. Please tick against each column towards acceptance (Wherever required, also mention make/other details of items).
	<p>(A) <u>Scope of Work:</u> -</p> <p>(1)The scope of work includes site study, design, manufacture, supply, installation, testing and commissioning of 12nos 3 pole, 11KV, 50HZ VCB panels indoor type including voltage transformers, current transformers, metering instruments, indications, protection relays etc as per the technical specifications after dismantling the old HT panel from 33KV Sub-station. This is a turnkey job; all the materials required for the satisfactory completion of the job should be supplied and installed by the supplier.</p> <p>The scope also includes removal of HT power and control cables from the existing HT panels and laying, terminating the same after installation of new panels. After erection of new panels due to any of the reasons if existing power cables found short then supplier has to lay new power cable. However, required power cable shall be provided by RSMML and cable end terminations shall be arranged by supplier.</p> <p>(2) The equipment offered shall be safe, reliable and compact to install. The workmanship shall be of high order. The circuit breaker and protective devices shall be of latest design so as to ensure</p>	

rapid and efficient interruption of fault current, low arc energy, small arcing time, complete phase segregation and freedom from fire hazards.

- (3) All of the twelve nos of VCB panels shall be connected with common bus bar system having 2 nos of incomers, 1no of buscoupler, 2nos of transformer feeders, 5nos of outgoing feeders, 1nos of DG breaker panels and 1 nos station transformer feeder panel. These panels shall be installed in place of existing 12nos of Voltas make fixed type 11KV SF6 breaker panels. Details of VCB panels are as below:-

- (a) Incomer panels, 1250Amp, 11KV.....**02 Nos**
- (b) Bus coupler panel 1250Amp, 11KV.....**01 No**
- (c) Transformer feeder panel 800 Amp, 11KV.....**02 Nos**
- (d) Outgoing feeder panels 800Amp, 11KV.....**05 Nos**
- (d) DG breaker panel 800Amp, 11KV...**01 No**
- (e) Station transformer feeder panel 630Amp, 11KV....**01No**

- (4) It is not the intent to specify herein all the details of design & manufacture. However, the equipment shall conform in all respect to high standards of design engineering and workmanship and shall be capable of performing in continuous efficient operation and conforming to the latest revision with amendment available of relevant standards, rules, and code.

(B) General Requirement: -

1. The VCB panels along with CT, PT, Control, indications, meters & relays shall be suitable for indoor Installations with vacuum as interrupting media incorporating separate interrupters for each phase mounted on single frame. There shall be a common drive mechanism actuating for interrupters, which must work in synchronism.
2. The operating mechanism of the circuit breaker shall be motor wound spring charged type. Anti pumping provision shall be provided. All working parts in the mechanism shall be of corrosion resistant material. Self-lubricating, wearing resistant bearings shall be provided in the mechanism. Spring charging through AC motor rated for 230VAC and should also have manually charging system. Suitable protection system to

	<p>prevent overcharging of spring in motorized & manual mode shall also be provided.</p> <ol style="list-style-type: none"> 3. Method of closing/tripping: (a) Electrically operated (b) Manual- ON/OFF push button 4. All the 12nos of VCBs shall be horizontal draw out type. The entire circuit breaker with its operating mechanism shall be mounted on a horizontal draw out type trolley mounted inserted into a floor standing sheet steel enclosure suitable for withstanding electromagnetic/ electro-dynamic forces of both symmetrical and asymmetrical faults 5. There shall be separate switches for controlling auxiliary supply (AC & DC) in each panel. 6. The circuit breaker panels should have safety shutter provision. 7. The VCB shall be provided with three distinct positions namely service, Test and Isolate in the panel and in all the position VCB should remain in the cubicle. 8. A mechanically operated circuit breaker position indicator shall be provided in a location visible from the operating side of the breaker without the necessity to open the mechanism door. The word 'OFF' in white letter on green background shall be used to indicate that the breaker is in the opening position and the word 'ON' in white letters on a red background to indicate that the breaker is in the closed position. These indications are in addition to the electrical indication. 9. The state of charge of the operating springs shall be indicated by a mechanical device showing 'SPRING CHARGED' when closing spring is fully charged and operation is permissible and 'SPRING FREE' when closing spring is not fully charged. 10. Mechanical counters to record the number of closing operations shall be provided for circuit breaker. 11. ON/NEUTRAL/ OFF control switch with rear terminal connections to be provided for breaker operation from panel. 12. MECHANICAL EMERGENCY TRIP DEVICE: Suitable for manual operation in the event of failure of electrical supplies. 13. Size of existing Voltas make ACB panel set is 11320X980X2600 cm (WXDXH) approx. Supplier 	
--	---	--

has to design the VCB panel set considering existing panel size limit. Dimensions of supplied panels shall match the existing foundation & cable trench. If any change is required in existing foundation and or cable trench, the same shall be in supplier's scope, inclusive of any civil or structural work. Proper gap should be maintained from wall side. Fixing of panel-The panel shall be installed on RCC/Trench.

GA drawing of existing panels with spacing from wall & roof is placed at Annexure-1(a) for reference purpose.

14. The panels should be designed based on safety to personal & equipment, reliability of service, easy of maintenance, interchangeability of equipment and ready addition of future loads.
15. The panel shall confirm to latest indian standards and electricity rules& regulations.
16. Switching duty: Overhead lines, transformer, pumps etc.
17. The panel shall also have a system to check the trip Ckt healthy system.
18. All the numerical relays and multifunctional energy meters used in panels shall have communication port. Numerical relays shall be draw out type with auxiliary supply of 110VDC and proper testing facility.
19. Built-in earth switches in all the feeders except incomers, DG breaker and bus-coupler panels (cable earth) shall be provided.
20. Particular of system: -
 - (a) Nominal system voltage.....11KV
 - (b) Highest system voltage12 KV
 - (c) Rated frequency50 Hz
 - (d) Number of phases.....03
 - (e) Neutral earthing..... Effectively earthed

- | | | |
|--|--|--|
| | <p>21. SERVICE CONDITIONS:-The equipment should operate satisfactorily under the climatic conditions specified which are as below:-</p> <p>(a) Peak ambient air temperature in shade.....50degree C</p> <p>(b) Minimum ambient air temperature in shade....</p> <p>(-) 5 degree C</p> <p>(c) Maximum relative humidity..... 95%</p> <p>(d) Minimum relative humidity..... 10%</p> <p>(e) Dusty environment due to active mining zone.</p> <p>22. All Routine tests of cubicle shall be carried out by the supplier in accordance with Indian standard (latest up to date) and test report shall be provided to RSMML.Bidder has to provide type test reports of VCB panels i.e. Temp rise, short circuit impulse, IP 4X and internal arc test 26.3KAfor 1sec along with the offer.</p> <p>23. Annunciation scheme -For each 11KV Switchgear panel of suitable numbers of windows Solid state with test, accept & reset facility & operating on110 DC power supply. One suitable hooter of 230VAC supply shall also be provide with each VCB panel.</p> <p>24. Required 230VAC and 110VDC shall be provided by RSMML for each panel.</p> <p>25. Space heaters- Suitable rating with Auto controlled by thermostat.</p> <p>26. 20% spare terminals and contacts to be provided for each terminal strip for each panel for future interconnection and interlocks.</p> <p>27. Illumination- LED lamps Auto controlled with door limit switches.</p> | |
|--|--|--|

28. List of spares required: - Following spares shall be provided by the supplier along with VCB panels-
- (i) Trip coil-**2 Nos**
 - (ii) Closing coil- **2 Nos**
 - (iii) Spring charging motor- **1 No**
 - (iv) VCB trolley- **1 No**
 - (v) Manual operating handles (spring/rack in/out)-
1 No for each VCB
 - (vi) Lockout Tagout kit for shut down purpose having 1no danger do not operate tag, 1no long shackle jacket padlock with three keys, 1no lockout tagout HASP.....**10Kits**
29. Safety Features: - The following interlocks shall be provided for service safety
- (a) Interlocking which prevents racking-in and racking-out of the circuit breaker when closed.
 - (b) Interlocking which prevents manual or electrical closing of the circuit breaker in the intermediate positions between connected or isolated.
 - (c) Shutter shall be provided with mechanism for automatic closing to prevent accidental contact with main stationary contacts or other live parts, when the breaker is drawn out. When the breaker is inserted into its cubicle, it shall automatically raise the shutters, allowing the breaker to continue its travel until it finally engages the main stationary contacts.
 - (d) Electrical interlock between two incomers and one bus-coupler as per CEAR2023.
 - (e) All the installed earth switches shall have electrically and mechanically interlocking with the respective VCB.

(C) Constructional specification: -The switchgear boards shall have a single front, single tier, fully compartmentalized, metal enclosed construction, comprising of row of freestanding floor mounted panels. The adjacent panels shall be completely separated by steel sheets except in busbar compartments where insulated barriers shall be provided to segregate adjacent panels. The circuit breakers shall be triple pole metal clad truck mounted horizontal draw out type enclosed in cubicle made of CRCA sheet steel of minimum 3 mm thickness and shall comply with latest edition of relevant IS. Other details are as below: -

1. Sheet thickness:

3mm CRCA sheet for Load bearing member

2mm CRCA for Non-Load bearing members
(Door & covers)

2. Degree of Protection: The functional unit outer enclosure shall have a degree of protection of IP4X.

3. Door will be provided with door lock and external pad lock arrangement for all panels. Suitable for log out/tag out system. All doors, removable covers and glass windows shall be gasketed all round with synthetic rubber or neoprene gaskets.

4. Color Shade: Powder Coating interior & Exterior surface- Light Grey

5. Main Bus-bar: Electrolytic Copper, Size: 50X10mm²/phase

6. Dropper Bus-bar for feeders- Electrolytic Copper, Size: 50X6mm²/phase

7. All Horizontal and vertical bus bars shall be provided with heat shrinkable PVC sleeves and supported on Epoxy supports.

8. Earth Bus-bar: Electrolytic Copper, size- 30X6mm²

9. Panels shall be dust & vermin proof.

	<p>10. Extensibility: On either side</p> <p>11. Interchangeability: Possible with breaker of same rating.</p> <p>12. The observation window on the circuit breaker compartment door shall be made of special toughened/laminated glass of at least 6mm thick.</p> <p>13. Feeder Name as specified in the drawing at Annexure-I(a) shall be provided on front & back side of each panel.</p> <p>14. One brass wiping gland for each breaker panel of adequate dimension for XLPE cable of 3 cores up to 185 sq. mm size shall be supplied along with panels.</p> <p>15. The cubicle shall comprise three high voltage compartments and one LV cabinet, as below: -</p> <ul style="list-style-type: none"> (i) Busbar compartment, tool accessible (ii) Circuit breaker compartment, interlock accessible (iii) Cable compartment, interlock accessible (iv) Low voltage cabinet <p>(D) <u>Incomer Breaker Panel.....</u>02Nos: -</p> <ol style="list-style-type: none"> 1. Cable Entry / Suitability of Termination- 3C X 185 sq.mm existing XLPE Cable. Provision for entry of incoming cable shall be from bottom of the panel. 2. <u>VCB details:</u> - Rated Current- 1250Amp, Insulation level: 28/75KV, Short circuit Breaking Current: SYM-26.3KA for 3sec, Making capacity: 50KApk, Duty: O-0.3sec-CO-3min-CO 3. Auxiliary circuit: 230VAC (For spring charging motor & space heater) & 110VDC (for closing, tripping & indicating ckt) 4. Protection: (a) 3 O/C & 1 E/F - Numerical type relay only. 	
--	---	--

	<p>(b) Separate static Earth leakage (30mA-30A) relay flush mounted with suitable CBCT.</p> <p>(c) Trip circuit supervision</p> <p>5. Metering- TVM Energy meter (provide by RSMML), Multifunctional energy meter, Digital Ammeter & Voltmeter</p> <p>6. Indications- ON, OFF, TRIP, Trip Ckt healthy, Spring charge, R/Y/B phase, Breaker position (Test/Service/Isolate), DC Fail.</p> <p>7. <u>Current transformer (CT)</u>: - 3Nos of ratio 200-100/1-1 A (Metering & O/C EF protection), 3Nos of ratio 200/0.577 A (Differential protection- Relay installed at 33KV side panel)</p> <p>8. <u>Protection Transformer (PT)</u>: -100VA, Accuracy Class-0.5, 11000/110Volt with fuse protection.</p> <p>(E) <u>Bus coupler Breaker Panel.....01No:</u> -</p> <p>1. <u>VCB details</u>: -Rated Current- 1250Amp, Insulation level: 28/75KV, Short circuit Breaking Current: SYM-26.3KA for 3sec, Making capacity: 50KApk, Duty: O-0.3sec-CO-3min-CO.</p> <p>2. <u>Auxiliary</u> circuit: 230VAC (For spring charging motor & space heater) & 110VDC (for closing, tripping & indicating ckt)</p> <p>3. <u>Protection</u>: (a) 3 O/C & 1 E/F - Numerical type relay only.</p> <p>(b) Separate static Earth leakage (30mA-30A) relay flush mounted with suitable CBCT.</p> <p>(c) Trip circuit supervision</p> <p>4. Metering- Multi functional Energy meter, Digital Ammeter</p> <p>5. Indications- ON, OFF, TRIP, Trip Ckt healthy, Spring charge, Breaker position (Test/Service/Isolate), DC Fail</p> <p>6. Suitable CTs shall also be provide for metering & protection. (3Nos CTS of ratio 200-100/1-1 A for Metering & O/C EF protection)</p>	
--	--	--

(F)Transformer Feeder Panel...02Nos (For switching 3MVA, 11/3.3KV transformer):-

1. Cable Entry / Suitability of Termination- 3C X 185 sq.mm existing XLPE Cable. Provision for entry of incoming cable shall be from bottom of the panel.
2. VCB Details: - Rated Current- 800Amp, Insulation level: 28/75KV, Short circuit Breaking Current: SYM-26.3KA for 3sec, Making capacity: 50KApk, Duty: O-0.3sec-CO-3min-CO.
3. Auxiliary circuit: 230VAC (For spring charging motor & space heater) & 110VDC (for closing, tripping & indicating ckt)
4. Protection:
 - (a) 3 O/C & 1 E/F - Numerical type relay only.
 - (b) Separate static Earth leakage (30mA-30A) relay flush mounted with suitable CBCT.
 - (c) Percentage differential protection relay.
 - (d) Transformer protection relay (WTI, OTI, Buchholz) with alarm and trip contacts.
 - (e) Trip circuit Supervision.
5. Metering- Multifunctional Energy meter, TVM Energy meter (provide by RSMML) & Ammeter.
6. Indications- ON, OFF, TRIP, Trip Ckt healthy, Spring charge, Breaker position (Test/Service/Isolate), DC Fail, Earth switch position (Close/open).
7. CTs:-3Nos of ratio 200-100/1-1 A (Metering & O/C EF protection), 3Nos of ratio 150/1 A (Differential protection).

(G)Outgoing feeder panel.....05Nos: -

1. Cable Entry / Suitability of Termination- 3C X 185 sq.mm existing XLPE Cable. Provision for entry of incoming cable shall be from bottom of the panel.
2. VCB Details: -Rated Current- 800Amp, Insulation level: 28/75KV, Short circuit Breaking Current: SYM-26.3KA for 3sec,

	<p>Making capacity: 50KApk, Duty: O-0.3sec-CO-3min-CO.</p> <ol style="list-style-type: none"> 3. Auxiliary circuit: 230VAC (For spring charging motor & space heater) & 110VDC (for closing, tripping & indicating ckt) 4. Protection: <ol style="list-style-type: none"> (a) 3 O/C & 1 E/F - Numerical type relay only. (b) Broken conductor protection. (c) Trip circuit supervision. (d) Separate static Earth leakage (30mA-30A) relay flush mounted with suitable CBCT. 5. Metering- Multifunctional energy meter, TVM energy meter (Provide by RSMML)& Ammeter 6. Indications- ON, OFF, TRIP, Trip Ckt healthy, Spring charge, Breaker position (Test/Service/Isolate), DC Fail, Earth switch position (Close/open). 7. Suitable CTs shall also be provided for metering & protection.(CTR:-200-100/1-1) <p>(H) <u>DG breaker panel.....</u>01No: -</p> <ol style="list-style-type: none"> 1. Cable Entry / Suitability of Termination- 3C X 185 sq.mm existing XLPE Cable. Provision for entry of incoming cable shall be from bottom of the panel. 2. <u>VCB Details:</u> -Rated Current- 800Amp, Insulation level: 28/75KV, Short circuit Breaking Current: SYM-26.3KA for 3sec, Making capacity: 50KApk, Duty: O-0.3sec-CO-3min-CO. 3. Auxiliary circuit: 230VAC (For spring charging motor & space heater) & 110VDC (for closing, tripping & indicating ckt) 4. Protection: <ol style="list-style-type: none"> (a) 3 O/C & 1 E/F -Numerical type relay only (b) Transformer protection relay (WTI, OTI, Buchholz) with alarm and trip contacts. (c) Trip circuit supervision. (d) Separate static Earth leakage (30mA-30A) relay flush mounted with suitable CBCT. 	
--	---	--

	<p>5. Metering- Digital Voltmeter, Ammeter, Multifunctional energy meter, TVM energy meter (Provide by RSMML)</p> <p>6. Indications- ON, OFF, TRIP, Trip Ckt healthy, Spring charge, Breaker position (Test/Service/Isolate), DC Fail.</p> <p>7. Suitable CTs shall also be provided for metering & protection. (CTR: - 120-60/1-1)</p> <p>8. Potential Transformer (PT):- 100VA, Accuracy Class-0.5, Ratio- 11000/110Volt with fuse protection.</p> <p>(I) <u>Station transformer feeder panel.....</u>01No: -</p> <p>1. Cable Entry / Suitability of Termination- 3C X 185 sq.mm existing XLPE Cable. Provision for entry of incoming cable shall be from bottom of the panel.</p> <p>2. <u>VCB Details</u>:-Rated Current- 630Amp, Insulation level: 28/75KV, Short circuit Breaking Current: SYM-26.3KA for 3sec, Making capacity: 50KApk, Duty: O-0.3sec-CO-3min-CO.</p> <p>3. Auxiliary circuit: 230VAC (For spring charging motor & space heater) & 110VDC (for closing, tripping & indicating ckt)</p> <p>4. Protection: (a) 3 O/C & 1 E/F - Numerical type relay only (b) Separate static Earth leakage (30mA-30A) relay flush mounted with suitable CBCT. (c) Trip circuit Supervision.</p> <p>5. Metering- Multifunctional energy meter, Ammeter.</p> <p>6. Indications- ON, OFF, TRIP, Trip Ckt healthy, Spring charge, Breaker position (Test/Service/Isolate), DC Fail, Earth switch position (Close/open).</p> <p>7. Suitable CTs shall also be provided for metering & protection. (C.T.R.:-100-50/1-1)</p>	
--	--	--


(J) OtherConditions: -

1. Supplier shall take suitable insurance policy for his workmen/employees before starting the work and submit a copy to RSMML.
2. Dismantling of existing switchgear panels shall also be in the scope of supplier.
3. Earthing of the new VCB panels is under the scope of supplier. However, the existing earth pit can be used for the same.
4. The Supplier is fully responsible for any damage to materials/property of RSMML and recovery will be made as per their present actual cost.
5. Bidder may visit the site prior to submit the tender to understand scope of work in better way.
6. All the required tools & tackles, crane shall also be arranged by the supplier only.
7. 3sets of drawings (Electrical & GI) in hard copy and one soft copy along with Routine test report as applicable shall be provided. The supplier is to be submit the drawings to RSMML after receiving purchase order for approval purpose.
8. All the manuals shall also be provided with the panel.
9. Required make of VCB: - ABB, Siemens, CGL, Schneider, L&T, Jyoti only
10. Required make for numerical relays: -ABB, Siemens, CGL, C&S, Schneider, GE, L&T only
11. Supplier shall also arrange for pre-dispatch inspection at manufacturer's works for RSMM Engineer and all the routine test as per the relevant Indian standard shall be carried out in his presence only.
12. Pre-commissioning tests: - Supplier has to conduct all the routine tests as per the applicable Indian standards of installed items i.e. VCB, CT, PT, Relays before commissioning at site and reports shall be submitted to RSMML before completion of work.

	<p>13. <u>Total shutdown requirement-</u></p> <p>The complete work shall be performed in two parts- One side of bus-coupler panel at one time and remaining after completion of previous. Each part shall be completed within 3 days max. Therefore, RSMML shall provide shutdown of 3 days max for each part which includes dismantling of old panels, installation & commissioning of new panels and other related work.</p> <p>The supplier has to inform to RSMML for the shutdown period before 7 days in advance.</p> <p>14. <u>TRAINING</u> -Training for operation & maintenance of relays and switchgear panels shall be provided on site to our personal for 2 days.</p>	
--	--	--

Date & Place:

Signature of tenderer with official stamp



e_TENDER NO. RSMM_CO_MM_NIT_13_2024-25

DECLARATION BY TENDERER

I/We declare that I am/ We are /manufacturer/ Authorized dealer Distributor in the goods/stores/equipments for which I/We have tendered.

If this declaration is found to be incorrect then without prejudice to any other action that may be taken, my/our bid security/security deposit may be forfeited in full and the tender if any to the extent accepted may be cancelled.

Signature of tenderer with official stamp

Date:

Place:

Note- Tenderers are requested to tick their status i.e. Manufacturer/ Authorised dealer / Distributor and attach supporting documents towards their status. In case of authorized dealers/channel partner, they should submit the authorization certificate from the respective VCB manufacturer.

e_TENDER NO. RSMM_CO_MM_NIT_13_2024-25**Details of past experience**

{To be submitted with Part-1 of the offer (Techno- commercial part)}

S. No.	Name & Address of the Purchaser	Order No. & Date	Brief Description of the work	Nos.	Specification of work	Date of Commissioning
01						
02						
03						
04						
05						
06						
07						

Note: Enclose copies of Purchase Orders and Installation/commissioning Certificate etc. as per PQC at clause no. 8.0.

Signature with Office Seal.

Place:

Date:

e_TENDER NO. RSMM_CO_MM_NIT_13_2024-25**PROFORMA OF GUARANTEE BOND FOR SECURITY DEPOSIT**

(To be issued by public Sector Banks & Private Sector banks as per schedule II of the Reserve Bank of India Act, 1954 as per list enclosed at annexure-X having its Branch office at Udaipur on the non-judicial stamp paper of value equal to @ 0.25% (zero-point twenty five percent) of the total Security Deposit Amount subject to maximum of Rs. 25000/- or as applicable at the time of submission of BG.

B.G. _____ Dated _____

Contact details of BG issuing Banker :

- Postal Address:-
- Telephone Nos.:-
- Fax No.:-
- e-mail Address:-
- Contact person e-mail:-

Contact details of Banker's local branch at Udaipur :

- Postal Address:-
- Telephone Nos.:-
- Fax No.:-
- e-mail Address:-
- Contact person e-mail:-

This Deed of Guarantee executed between _____ having its registered office at (mention complete postal address with contact nos./mail address etc.)_____ and its head office at (mention complete postal address with contact nos./mail address etc.)_____ and wherever the context so required include its successors and assignees (hereinafter called the Surety/Bank) AND Rajasthan State Mines and Minerals Limited, a company incorporated and registered under Indian companies Act, 1956, having its registered office at C-89/90 Lal Kothi Scheme, Janpath, Jaipur and Corporate office at 4 Meera Marg, Udaipur and wherever its context so required includes its successors and assignees (hereinafter called 'the company').

Whereas the Company having agreed to exempt M/s. _____ a company/partnership firm _____ (address of registered/H.O.) where ever the context so require includes its successors and assignees (hereinafter called 'the Contractor/supplier/RC holder') from the demand under the terms and conditions of Letter of Acceptance/ Purchase Order/ Rate Contract no. _____ dated _____ issued in favour of the Contractor/supplier/RC holder, hereinafter called 'the said Letter of Acceptance/ Purchase Order/ Rate Contract' which expression shall also include any amendment, modification or variations thereof made in accordance with the provision thereof, of cash security deposit for the due fulfillment by the said Letter of Acceptance/ Purchase Order/ Rate Contract on production of unconditional and irrevocable Bank Guarantee for Rs. _____(Rs. _____) being Contract .

Now this deed witnesseth that in consideration of said bank having agreed on the request of the Contractor/supplier/RC to stand as surety for payment of Rs. _____ as security deposit to the company subject to the following conditions.

1. We, _____ (Bank) do hereby undertake to pay to the company as amount not exceeding Rs. _____ against any loss or damage caused to or

suffered or would be caused to or suffered by the company by reason of any breach by the said contractor/supplier/RC holder of any of the terms and/or conditions contained in the Letter of Acceptance/ Purchase Order/Rate Contract. The decision of the Company, as to any such breach having been committed and loss/damage suffered to shall be absolute and binding on us.

2. We, _____ (bank) do hereby undertake without any reference to the Contractor/supplier/RC holder or any other person and irrespective of the fact whether any dispute is pending between the Company and the Contractor/supplier/RC holder before any court or tribunal or Arbitrator relating thereto, to pay the amount due and payable under this guarantee without any demur, and/or protest merely on the very first demand from the Company stating that the amount claimed is due by way of loss or damage caused to or suffered by or would be caused to or suffered by the Company by reason of any breach by the said contractor/supplier/RC holder of any of the terms and conditions contained in the said Letter of Acceptance/ Purchase Order/ Rate Contract by reason of the said contractor's/supplier's/RC holder's failure to perform the covenants contained in said Letter of Acceptance/ Purchase Order/ Rate Contract. Any such demand made on the bank shall be conclusive, absolute and unequivocal as regards the amount due and payable by the bank under this guarantee. However, bank's liability under this guarantee shall be restricted to an amount not exceeding Rs. _____.
3. We, _____ (bank) further agree that the guarantee herein above contained shall remain in full force and effect during the period that would be taken for the performance of the contract and that it shall continue to be enforceable till all the dues of the company under or by virtue of the contract have been fully paid and its claim/s satisfied or discharged or till the company certifies that the terms and the conditions of the said Letter of Acceptance/ Purchase Order/ Rate Contract have been fully and properly carried out by the said contractor/supplier/RC holder and accordingly discharges the guarantee, unless a demand or claim under this guarantee is made on the bank in writing on or before _____ (scheduled completion date, plus six months or period which is required), the bank shall be discharged from all liability under this guarantee thereafter unless otherwise further extended by the bank.
4. In order to give full effect to the guarantee herein contained the company shall be entitled to act as if, we(bank) are your principal debtor in respect of all your claims against the Contractor/supplier/RC holder hereby guaranteed by us as aforesaid and we hereby expressly waive all our rights of surety-ship and other rights, if any which are in any way inconsistent and/or contrary to the above or any other provision of this guarantee, the bank's guarantee to pay hereunder will not be determined or affected by your proceeding against the Contractor/supplier/RC holder and the bank will be liable to pay the said sum as and when demanded by you merely on first demand being made on the bank by you and even before any legal or other proceedings taken against the contractor/supplier/RC holder. Any letter of demand delivered at the bank's above branch/divisional office or Udaipur branch office _____ (specify the name & address) under the signatures of the company's Financial Advisor/ Group General Manager/ General Manager or any of the Directors shall deemed to be sufficient demand under this guarantee.
5. We, _____ (bank) further agree that the company shall have the fullest liberty without our consent and without affecting in any manner our obligation hereunder to vary any of the terms and conditions of the said letter/Purchase Order/ or to extend time of performance by the said supplier/RC from time to time or to postpone for any time or from time to time any of the powers exercisable by the Company against the said Contractor/supplier/RC and to for bear or enforce any of the terms and conditions relating to the Purchase Order/and we shall not be relieved from our liability by reason of any such variation or extension being granted to the said contractor/supplier/RC holder or for any fore bearance act, or omissions on the part of

the company or any indulgence of the Company to the said Contractor/supplier/RC holder or by any such matter or things whatsoever which under the law relating to the sureties would but for this provisions have effect of so relieving us.

6. This guarantee herein contained would come into force from the date of issue and would not be affected by any change in the constitution of the supplier/RC or ourselves or liquidation or winding up or dissolution or insolvency of the contractor/supplier/RC holder nor shall it be affected by any change in company's constitution or by any amalgamation or any absorption thereof or therewith but shall ensure for and be available to and enforceable by absorbing or amalgamated company or concern till the payment or amount not exceeding Rs. _____ is made by the Bank.
7. The guarantee will not be discharged or affected if the Company holds/obtain any other security/guarantee/promissory note from any person and/or the contractor/supplier/RC holder and this guarantee shall be in addition to any such guarantees.
8. We, _____ (Bank) lastly undertake not to revoke this guarantee during this currency except with the previous consent of the company in writing.
9. The bank has power to issue this guarantee in favour of the Company and the undersigned has full powers to do so under power of Attorney dated _____ granted to him by the bank.
10. For the purpose of enforcing legal rights in respect of this guarantee only Udaipur courts in the state of Rajasthan alone shall have jurisdiction, exclusively.

IN WITNESSETH I, _____ SON OF _____ (designation) _____ (branch) constituted attorney of the said bank have set my signatures and bank seal on this guarantee which is being issued on non-judicial stamp of proper value as per Stamp Act prevailing in the state of _____ executed at _____ this the _____ day of _____ 2025.

e_TENDER NO. RSMM_CO_MM_NIT_13_2024-25**Public Sector Banks & Private Sector banks as per schedule II of the Reserve Bank of India Act, 1954****List of Scheduled Public Sector Banks**

S.No.	Name of the Bank
1	Bank of Baroda
2	Bank of India
3	Bank of Maharashtra
4	Canara Bank
5	Central Bank of India
6	Indian Bank
7	Indian Overseas Bank
8	Punjab & Sind Bank
9	Punjab National Bank
10	UCO Bank
11	Union Bank of India
12	State Bank of India

List of Scheduled Private Sector Banks

S.No.	Name of the Bank
1	Axis Bank Limited
2	Bandhan Bank Limited
3	CSB Bank Limited
4	City Union Bank Limited
5	DCB Bank Limited
6	Dhan Laxmi Bank Limited
7	Federal Bank Limited
8	HDFC Bank Limited
9	ICICI Bank Limited
10	IndusInd Bank Limited
11	IDFC FIRST Bank Limited
12	Jammu & Kashmir Bank Limited
13	Karnataka Bank Limited
14	Karur Vysya Bank Limited
15	Kotak Mahindra Bank Limited
16	Nainital Bank Limited
17	RBL Bank Limited
18	South Indian Bank Limited
19	Tamilnad Mercantile Bank Limited
20	YES Bank Limited
21	IDBI Bank Limited
22	AU Small Finance Bank

Annexure –XI

e_TENDER NO. RSMM_CO_MM_NIT_13_2024-25

Format of Undertaking

(on non-judicial stamp paper of appropriate value)

Name of contractor/supplier.....

I.....S/o.....Sh.....aged.....years.....resident

of.....on.....behalf.....of.....i.e.....M/s

.....hereby undertake that I have submitted bank guarantee

Bearing BG no.....for amount Rs.issued by

.....bank having branchfor the work of

.....(reference of tender & work).

I/we undertake that in case of liquidation of BG issuance bank for any reason,
I/we will submit new BG of same amount with in a period of 10 days, failing which
the company may take any appropriate action as deemed fit.

Signature of Contractor/Supplier(S)
(Authorized Signatory)
With Seal

Place:

Date:

e_TENDER NO. RSMM_CO_MM_NIT_13_2024-25

FORM OF BID-SECURING DECLARATION (Applicable only for the bidders fall in the category of bidders as per clause no. 6.0 (B) of tender
(To be typed on non judicial stamp paper of valuing Rs. 50/-)

Date:

Bid No.:

Alternative No.:

To:

We, the undersigned, declare that:

We understand that, according to your conditions, bids must be supported by a Bid-Securing Declaration.

We accept that we are required to pay the bid security amount specified in the Term and Condition of Bid,

In the following cases, namely:-

- (a) when we withdraw or modify our bid after opening of bids;
- (b) when we do not execute the agreement, if any, after placement of supply/work order with in the Specified period;
- (c) when we fail to commence the supply of the goods or service or execute work as per supply/work Order within the time specified;
- (d) when we do not deposit the performance security within specified period after the supply/work Order is placed ;and
- (e) if we breach any provision of code of integrity prescribed for bidding specified in the Act and Chapter VI of these rules.

In addition to above, the State Government shall debar us from participating in any procurement process Undertaken for a period not exceeding three years in case where the entire bid security or any part thereof is required to be forfeited by procuring entity.

We understand this bid securing declaration shall expire if:-

- (i) we are not the successful bidder;
- (ii) the execution of agreement for procurement and performance security is furnished by us in case we are successful bidder;
- (iii) thirty days after the expiration of our bid.
- (iv) the cancellation of the procurement process ;or
- (v) the withdrawal of bid prior to the deadline for presenting bids, unless the bidding documents stipulate that no such withdrawal is permitted.

Signed.:-----

Name :-----

In the capacity of:-----

Duly authorized to sign the bid for and on behalf of:

Dated on day of

Corporate seal-----

[Note: In case of a Joint Venture, the bid securing declaration must be signed in name of all Partners of the joint venture that is submitting the bid,]

e_TENDER NO. RSMM_CO_MM_NIT_13_2024-25

FORMAT OF DECLARATION IN LIEU OF SECURITY DEPOSIT CUM PERFORMANCE GUARANTEE IN CASE OF AWARD OF CONTRACT(Applicable only for the bidders fall in the category of bidders as per clause no. 6.0 (B) of tender

To: RSMML

We, the undersigned, declare that:

We understand that, according to your conditions, the Contract must be supported by a Performance Security Declaration as a guarantee to ensure fulfillment of our all-performance obligations under the Contract for above mentioned tender.

We accept that we will automatically be suspended from being eligible for bidding in any contract with you for the suitable time if we are in breach of any of our performance obligation under the conditions of the Contract. We further understand this Performance Security Declaration shall expire after 60 days of completion of our all obligations under the Contract including Defect Liability, warranty/Guarantee, operation, maintenance, etc. in accordance with the conditions of the Contract.

Signature of tenderer with official stamp

Date:

Place

e_TENDER NO. RSMM_CO_MM_NIT_13_2024-25

Annexure A : Compliance with the Code of Integrity and No Conflict of Interest

Any person participating in a procurement process shall –

- a) Not misrepresent or omit that misleads or attempts to mislead so as to obtain a financial or other benefit or avoid an obligation;
- b) Not offer any bribe, reward or gift or any material benefit either directly or indirectly in exchange for an unfair advantage in procurement process or to otherwise influence the procurement process;
- c) Not indulge in any collusion, bid rigging or anti-competitive behavior to impair the transparency, fairness and progress of the procurement process;
- d) Not misuse any information shared between the procuring Entity and the Bidders with an intent to gain unfair advantage in the procurement process;
- e) Not indulge in any coercion including impairing or harming or threatening to do the same, directly or indirectly, to any party or to its property to influence the procurement process;
- f) Not obstruct any investigation or audit of a procurement process;
- g) Disclose conflict of interest, if any, and
- h) Disclose any previous transgressions with any Entity in India or any other country during the last three years or any debarment by any other procuring entity.

Conflict of Interest :-

The Bidder participating in a bidding process must not have a Conflict of Interest.

A Conflict of Interest is considered to be a situation in which a party has interests that could improperly influence that party's performance of official duties or responsibilities, contractual obligations, or compliance with applicable laws and regulations.

- 1) A Bidder may be considered to be in Conflict of Interest with one or more parties in a bidding process if, including but not limited to:
 - a) Have controlling partners/shareholders in common; or
 - b) Receive or have received any direct or indirect subsidy from any of them; or
 - c) Have the same legal representative for purposes of the bid; or
 - d) Have a relationship with each other, directly or through common third parties, that puts them in a position to have access to information about or influence on the bid of another Bidder, or influence the decisions of the Procuring Entity regarding the bidding process; or
- e) The Bidder participates in more than one bid in a bidding process. Participation by a Bidder in more than one bid will result in the disqualification of all bids in which the Bidder is involved. However, this does not limit the inclusion of the same subcontractor, not otherwise participating as a Bidder, in more than one bid; or
- f) The Bidder or any of its affiliates participated as a consultant in the preparation of the design or technical specifications of the Goods, Works or Services that are the subject of the bid; or
- g) Bidder or any of its affiliates has been hired (or is proposed to be hired) by the Procuring Entity as engineer-in-charge/consultant for the contract.

e_TENDER NO. RSMM_CO_MM_NIT_13_2024-25
Annexure B: Declaration by the Bidder regarding qualifications
Declaration by the Bidder

In relation to my/our Bid submitted tofor procurement ofin response to their Notice Inviting Bids No..... datedI/we hereby declare under Section 7 of Rajasthan Transparency in Public Procurement Act 2012, that :

1. I/we possess the necessary professional, technical, financial and managerial resources and competence required by the Bidding Document issued by the Procuring Entity;
2. I/we have fulfilled my/our obligation to pay such of the taxes payable to the Union and the State Government or any local authority as specified in the Bidding Document;
3. I/we are not insolvent, in receivership, bankrupt or being wound up, not have my/our affairs administered by a court or a judicial officer, not have My/our business activities suspended and not the subject of legal proceedings for any of the foregoing reasons;
4. I/we do not have, and our directors and officers not have been convicted of any criminal offence related to my/our professional conduct or the making of false statements or misrepresentations as to my/our qualifications to enter into a procurement contract within a period of three years preceding the commencement of this procurement process, or not have been otherwise disqualified pursuant to debarment proceedings;
5. I/we do not have a conflict of interest as specified in the Act, Rules and the Bidding Document, which materially affects fair competition;

Signature of bidder

Name:

Designation:

Address:

Date:

Place:

Annexure C: Grievance Redressal during Procurement Process

The designation and address of the First Appellate Authority is: Mines Dept, Govt. of Rajasthan.

The designation and address of the Second Appellate Authority is: Finance Dept., Govt. of Rajasthan.

1. Filing an appeal

If any Bidder or prospective bidder is aggrieved that any decision, action or omission of the Procuring Entity is in contravention to the provisions of the Act or the Rules or the Guidelines issued thereunder, he may file an appeal to First Appellate Authority, as specified in the Bidding Document within a period of ten days from the date of such decision or action, omission, as the case may be clearly giving the specific ground or grounds on which he feels aggrieved:

Provided that after the declaration of a Bidder as successful the appeal may be filed only by a Bidder who has participated in the procurement proceedings:

Provided further that in case a Procuring Entity evaluates the technical bids before the opening of the financial Bids, an appeal related to the matter of Financial Bids may be filed only by a Bidder whose Technical Bid is found to be acceptable.

2. The officer to whom an appeal is filed under para (1) shall deal with the appeal as expeditiously as possible and shall endeavor to dispose it of within thirty days from the date of the appeal.
3. If the officer designated under para (1) fails to dispose of the appeal filed within the period specified in para (2) or if the Bidder or prospective bidder or the Procuring Entity is aggrieved by the order passed by the First Appellate Authority, the bidder or prospective bidder or the Procuring Entity, as the case may be, may file a second appeal to Second Appellate Authority specified in the Bidding Document in this behalf within fifteen days from the expiry of the period specified in para (2) or of the date of receipt of the order passed by the First Appellate Authority, as the case may be .

4. Appeal not to lie in certain cases

No appeal shall lie against any decision of the Procuring Entity relating to the following matters, namely:-

- a. Determination of need of procurement;
- b. Provisions limiting participation of Bidders in the Bid process;
- c. The decision of whether or not to enter into negotiations ;
- d. Cancellation of a procurement process;
- e. Applicability of the provisions of confidentiality.

5. Form of Appeal

- a. An appeal under para (1) or (3) above shall be in the annexed form along with as many copies as there are respondents in the appeal;
- b. Every appeal shall be accompanied by an order appealed against, if any, affidavit verifying the facts stated in the appeal and proof of payment of fee.
- c. Every appeal may be presented to First Appellate Authority or Second Appellate Authority, as the case may be, in person or through registered post or authorized representative.

6. Fee for filing appeal

- a. Fee for the first appeal shall be rupees two thousand five hundred and for second appeal shall be rupees ten thousand, which shall be non-refundable.
- b. The fee shall be paid in the form of bank demand draft or bankers' cheque of a Scheduled Bank in India payable in the name of Appellate Authority concerned.

7. Procedure for disposal of appeal

- a. The First Appellate Authority or Second Appellate Authority, as the case may be, upon filing of appeal, shall issue notice accompanied by copy of appeal, affidavit and documents, if any, to the respondents and fix date of hearing.
- b. On the date fixed for hearing, the First Appellate Authority or Second Appellate Authority, as the case may be, shall –
 - i) Hear all the parties to appeal present before him; and
 - (ii) Peruse or inspect documents, relevant records or copies thereof relating to the matter.
- c. After hearing the parties, perusal or inspection of documents and relevant records or copies thereof relating to the matter, the Appellate Authority concerned shall pass an order in writing and provide the copy of order to the parties to appeal free of cost.
- d. The order passed under sub-clause (c) above shall also be placed on the State Public Procurement Portal.

Memorandum of Appeal under the Rajasthan Transparency in Public Procurement Act 2012

Appeal No..... of

Before the(First / Second Appellate Authority)

1. Particulars of appellant :
 (i) Name of the appellant :
 (ii) Official address, if any:
 (iii) Residential address:
2. Name and address of the respondent(s) :
 (i)
 (ii)
 (iii)
3. Number and date of the order appealed against and name and designation of the officer/authority who passed the order (enclose copy), or a statement of a decision, action or omission of the Procuring Entity in contravention to the provisions of the Act by which the appellant is aggrieved:
4. If the Appellant proposes to be represented by a representative, the name and postal address of the representative :
5. Number of affidavits and documents enclosed with the appeal :
6. Ground of appeal

(Supported by an affidavit)
7. Prayer:.....

Place :

Date:

Appellant's signature :

Annexure D : Additional Conditions of Contract

1. Correction of arithmetical errors

Provided that a Financial Bid is substantially responsive, the Procuring Entity will correct arithmetical errors during evaluation of Financial Bids on the following basis:

- (i) if there is a discrepancy between the unit price and the total price that is obtained by multiplying the unit price and quantity, the unit price shall prevail and the total price shall be corrected, unless in the opinion of the Procuring Entity there is an obvious misplacement of the decimal point in the unit price, in which case the total price as quoted shall govern and the unit price shall be corrected;
- (ii) If there is an error in a total corresponding to the addition or subtraction of sub totals, the subtotals shall prevail and the total shall be corrected; and
- (iii) If there is a discrepancy between words and figures, the amount in words shall prevail, unless the amount expressed in words is related to an arithmetic error, in which case the amount in figures shall prevail subject to (i) and (ii) above.

If the Bidder that submitted the lowest evaluated bid does not accept the correction of errors, its bid shall be disqualified and its Bid Security shall be forfeited or its Bid Securing Declaration shall be executed.

2. Procuring Entity's Right to Vary Quantities

- (i) At the time of award of contract, the quantity of Goods, works or services originally specified in the Bidding Document may be increased or decreased by a specified percentage, but such increase or decrease shall not exceed twenty percent, of the quantity specified in the Bidding Document. It shall be without any change in the unit price or other terms and conditions of the bid and the conditions of contract.
- (ii) If the Procuring Entity does not procure any subject matter of procurement procures less than the quantity in the Bidding Document due to change in circumstances, the bidder shall not be entitled for any claim or compensation except otherwise provided in the conditions of contract.
- (iii) In case of procurement of goods or services, additional quantity may be procured by placing a repeat order on the rates and conditions of the original order. However, the additional quantity shall not be more than 50% of the value of goods of the original contract and shall be within one month from the date of expiry of last supply. If the supplier fails to do so, Procuring Entity shall be free to arrange for the balance supply by limited bidding or otherwise and the extra cost incurred shall be recovered from the supplier.

3. Dividing quantities among more than one bidder at the time of award (In case of procurement of goods)

As a general rule all the quantities of the subject matter of procurement shall be procured from the bidder, whose bid is accepted. However, when it is considered that the quantity of the subject matter of procurement to be procured is very large and it may not be in the capacity of the bidder, whose bid is accepted, to deliver the entire quantity or when it is considered that the subject matter of procurement to be procured is of critical and vital nature, in such cases, the quantity may be divided between the bidder, whose bid is accepted and the second lowest bidder or even more bidders in that order, in a fair, transparent and equitable manner at the rates of the bidder, whose bid is accepted.

Form A
(Apply in Duplicate)

Application by MSME for Purchase Preference in Procurement of Goods

To,
The General Manager
DIC, District

1. Name of Applicant with Post:
2. Permanent Address:
3. Contact Details:
 - a. Telephone No.:
 - b. Mobile No.:
 - c. Fax No.:
 - d. Email Address:
4. Name of micro & small enterprise:
5. Office Address:
6. Address of Work Place:
7. No. & Date of Entrepreneurs Memorandum-II/Udyog Aadhaar Memorandum:
(enclose photo copy):
8. Products which Entrepreneurs Memorandum-II/Udyog Aadhaar Memorandum
availed:
9. Products which are at present being produced by the enterprise:
10. Products for which purchase preference has been applied for:
11. Production capacity as per Capacity Assessment Certificate (enclose photocopy of
Capacity Assessment Certificate):

Serial No.	Product	Product Production Capacity	
		Quantity	Value
1			
2			
3			
4			

12. List of Plant & Machinery installed:

Serial No.	Name of Plant & Machinery	Quantity	Value
1			
2			
3			
4			

13. List of Testing Equipment's installed:

Serial No.	Name of Testing Equipments	Quantity	Value
1			
2			
3			
4			

14. Benefits availed in last financial year and current financial year:

a. Benefits depositing Bid Security and Performance Security:

Last Financial Year			Current Financial Year	
Department	Bid Security	Performance Security	Bid Security	Performance Security

b. Details of Supply orders received:

Last Financial Year				Current Financial Year		
Department	No. & Date of purchase order	Amount for which purchase order received	Amount of goods supplied	No. & Date of purchase order	Amount for which purchase order received	Amount of goods supplied

I declare that the above all facts given in the application are correct and my enterprise is producing the items mentioned in column No. 10.

Date

Signature
(Name of the applicant
along with seal of post)

Office of the District Industries Centre _____

CERTIFICATE

File No. _____

Date _____

It is certified that M/s _____ was inspected by _____ on dated _____ and the facts mentioned by the enterprise are correct as per the record shown by the applicant. The enterprise is eligible for Purchase Preference under this notification.

The certificate is valid for one year from the date of its issue.

Office Seal Signature

(Full Name of the Officer)
General Manager
District Industries Centre
Rubber Seal/Stamp

Enclosure-
(1) Application

Format of Affidavit

IS/oAged Yrs. residing at
 Proprietor/Partner/Director of M/s
 do hereby solemnly affirm and declare that :

(a) My/Our above noted enterprise M/s has been issued acknowledgement of Entrepreneurial Memorandum Part - II by the District Industries Center The acknowledgement No. is dated and has been issued for manufacture of following items:

Name of Item	Production Capacity (Yearly)
--------------	------------------------------

- (i)
- (ii)
- (iii)
- (iv)
- (v)

(b) My/Our above noted acknowledgment of Entrepreneurial Memorandum Part - II has not been cancelled or withdrawn by the Industries Department and that the enterprise is regularly manufacturing the above items.

(c) My/Our enterprise is having all the requisite plant and machinery and is fully equipped to manufacture the above noted items.

Place _____

Signature of
 Proprietor/ Director Authorized Signatory
 with Rubber Stamp and date