



# RAJASTHAN STATE MINES & MINERALS LIMITED

(A Govt. of Rajasthan Enterprise)

Registered Office  
C89-90, Lal Kothi Scheme, Janpath  
Jaipur (Rajasthan)India  
Ph.:+91-1410-2743734. 2743934  
Fax: +91-141-2743735

**CIN No.: U14109RJ1949SGC00050**

**PAN No : AAACR7857H**

**GSTIN No. 08AAACR7857 H1Z0**

Corporate Office  
4, Meera Marg,  
Udaipur – 313 001

Ph.:+91-294-2428768,2428763-67

Fax:+91-294-24287,2428739

e-mail naveengupta.rsmml@rajasthan.gov.in

website: [www.rsmm.com](http://www.rsmm.com)

Ref. No. RSMM/CO/MM/NIT-2/2022-23

Date: 13.06.2022

## **CORRIGENDUM NO.3**

Sub.- e\_TENDER NO. RSMM\_CO\_MM\_NIT\_02\_2022-23 Dated 06.05.2022  
FOR SITE STUDY, DESIGN, MANUFACTURER, SUPPLY, INSTALLATION,  
TESTING AND COMMISSIONING OF 10 NOS 3 POLE, 3.3KV, 50HZ VCB  
PANELS INDOOR TYPE INCLUDING VOLTAGE TRANSFORMERS, CURRENT  
TRANSFORMERS, METERING INSTRUMENTS, INDICATIONS, PROTECTION  
RELAYS ETC AS PER THE TECHNICAL SPECIFICATION AFTER DISMANTLING  
THE OLD HT PANEL FROM 33KV SUB-STATION AS PER TERMS AND  
CONDITIONS OF TENDER AT JHAMARKOTRA MINES LOCATED ABOUT 25  
KMS FROM UDAIPUR.

Against the above mentioned tender, following amendment is being made:

Ref. of clause no.	Amendment
NIT, Annexure-VI, Point-11, Para D-4, E-3, F-4, G-3 or any other places.	<p><u>Bidders are to consider Numerical type protection relays instead of Electro-mechanical type protection relays wherever mentioned in the technical specifications(Annexure-VI), details of required numerical relays are as below:</u></p> <p><b>“Draw out type numerical relays with communication port, minimum 2 stages and user configurable curve characteristics, auxiliary supply 110VDC with proper testing facility.</b></p> <p><b>Acceptable make of numerical relays: Areva, Alstom, Schneider, ABB, C&amp;S, Siemens, GE, CGL and L&amp;T.</b></p>

### **Note:**

- Bidders are requested to enclose sealed & signed copy of this corrigendum no. 3 alongwith part-I of their offer towards acceptance of amendment made, as above.
- Except above, all other specifications of all items and terms & conditions of tender will remain unchanged.

For more details, tenderer may contact DGM (MM) at the above address.

(L.S.Sardalia)  
Group General Manager (MM)